



# C E R T I F I C A T E

Certificate No 09-PPV-00030/03-M03-TIC

WE HEREBY CERTIFY THAT THE PHOTOVOLTAIC MODULES WITH THE MODELS

YUR.POWER A-M 272, YUR.POWER A-M 227, YUR.POWER A-M 204,  
YUR.POWER A-M 182, YUR.POWER A-M 136  
PPV-272S6 ( Tested types )

OEM APPLICANT & LICENSE HOLDER

YURAKU PTE LTD

40 Ubi Crescent #01-02 Ubi Techpark S(408567)

IS IN COMPLIANCE WITH THE REQUIREMENTS OF

IEC 61215 : 2005

Crystalline silicon terrestrial photovoltaic (PV) modules – Design qualification and type approval  
&

EN 61730-1 / EN 61730-2 : 2007

Photovoltaic (PV) module safety qualification

To be used in plants at a total voltage up to : 1000 Vdc

AS RESULT OF THE TEST IN OUR APPOINTED LABORATORY

EUROTEST LABORATORI

(EA ACCREDITED LABORATORY N. 0192)

REPORT No. TIC-PVC01CdO08C364002

Expiring date 11.01.2012

( Providing that the testing basis continues unchanged )

**Notes:** (\*)The manufacturer declares that these products are constructed using the same materials, components and processes as the tested type PPV-272S6. Further details on certified models, are reported on the attachment. Technical data, materials and components description are into the indicated test reports. Any changes of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval. The certification is performed on tested model as retest according to IEC61730 "Retesting guideline" for similarity with model PPV-260M6 with differences in cell technology (certificate n° C01 08C364001 released by Eurotest Laboratori in date 10/10/2008). This certificate is for type approval and based on voluntarily product test without Factory Inspection.



Am Bonner Bogen 2, D-53227 Bonn, 05.05.2008

TUV INTERCERT Certification Body

CERTIFICATE • CERTIFICATO • ZERTIFIKAT • SERTIFIKA • CERTIFICADO • گواهینامه • ΠΙΣΤΟΠΟΙΗ

CERTIFICATE • CERTIFICATO • ZERTIFIKAT • SERTIFIKA • CERTIFICADO • گواهینامه • ΠΙΣΤΟΠΟΙΗ