

Certificate

Registration No.: PV 50187536

Page 1

Report No.: 12017144 015

License Holder:

YURAKU PTE LTD
11 COLLYER QUAY
#10-04 THE ARCADE 049317
SINGAPORE

Product:

PV Module
Type: S-P 200, S-P 205, S-P 210
S-P 215, S-P 220, S-P 225
S-P 230, S-P 235, S-P 265
S-P 270, S-P 275

Manufacturing Plant:

0002-12017144 001

Basis:

IEC 61215:2005
EN 61215:2005
"Crystalline silicon terrestrial
photovoltaic (PV) modules - Design
qualification and type approval"

Factory Inspection
To document the consistent quality of
the product factory inspections are
performed periodically.



- **Periodic inspection**
- **Qualified, IEC 61215**
- **Safety tested, IEC 61730**

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 12 January 2014.



Certification body



Dipl.-Ing. W. Herlitschke

Yokohama, 26 August 2010

TÜV Rheinland Japan Ltd. – Yokohama 222-0033, Japan

Certificate

Registration No.: PV 50187537

Page 1

Report No.: 12017144 016

License Holder:
YURAKU PTE LTD
11 COLLYER QUAY
#10-04 THE ARCADE 049317
SINGAPORE

Product:
PV Module
Type: S-P 200, S-P 205, S-P 210
S-P 215, S-P 220, S-P 225
S-P 230, S-P 235, S-P 265
S-P 270, S-P 275

Manufacturing Plant:
0002-12017144 002

Basis:

IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

Factory Inspection
To document the consistent quality of the product factory inspections are performed periodically.



- Periodic inspection
- Qualified, IEC 61215
- Safety tested, IEC 61730

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 12 January 2014.



Certification body



Dipl.-Ing. W. Herlitschke

Yokohama, 26 August 2010

TÜV Rheinland Japan Ltd. – Yokohama 222-0033, Japan